



DEPARTMENT OF ENVIRONMENTAL QUALITY

KATHLEEN BABINEAUX BLANCO

GOVERNOR

MIKE D. McDANIEL, Ph.D.

SECRETARY

Certified Mail# _____

File No.: LA0003191

AI No.: 687

Activity No.: PER20060002

Mr. Gus M. VonBodungen
Entergy Louisiana, L.L.C.
Little Gypsy Generating Plant
Post Office Box 61000, Mail Unit L-ENT-5E
New Orleans, Louisiana 70161

RE: Draft Major Modification of Louisiana Pollutant Discharge Elimination System (LPDES)
permit LA0003191

Dear Mr. VonBodungen:

Your request received on May 8, 2006 regarding the modification of LPDES permit LA0003191 has been evaluated. The draft modification(s) are as follows:

1. In accordance with the settlement agreement between Entergy and LDEQ and the requirements outlined in LDEQ's July 8, 2005 letter of agreement, Outfalls 004, 005 and 006 have been changed to become effective only after circumstances outlined in Part II, Paragraph O.6 occur. The wastewater descriptions for Outfalls 004, 005 and 006 are being revised as per Entergy's modification request.
2. Part II, Paragraph O.6 (Stormwater Discharges) has been revised to incorporate the new Stormwater Pollution Prevention Plan requirements which were outlined in LDEQ's July 8, 2005 letter.
3. The company name on the permit and title page has been changed to Entergy Louisiana, L.L.C.

Attached are the draft revisions to Part I of the permit (Effluent Limitations, Part I, pages 7, 8, 9, of 9), the modified Part II pages, and the modified Title Page for the requested modifications. Please note that this is a DRAFT MODIFICATION only. Authorization to change your discharge will be granted only upon the receipt of an approved modification from this Office. All other conditions of the permit LA0003191 shall continue unchanged and remain valid until the expiration date of the permit. In accordance with LAC 33:IX.3105.B.2, only those permit limitations and conditions pertaining to the draft modification(s) are open for public comment.

ENVIRONMENTAL SERVICES

: PO BOX 4313, BATON ROUGE, LA 70821-4313

P:225-219-3181 F:225-219-3309

WWW.DEQ.LOUISIANA.GOV

Entergy Louisiana, L.L.C.
LA0003191 / AI 687
Page 2

This Office will publish the enclosed public notice one time in a local newspaper of general circulation and the Office of Environmental Services Public Notice Mailing List. In accordance with LAC 33:IX.6521.A, the applicant shall receive and is responsible for paying the invoice(s) from the above mentioned newspaper. LAC 33:IX.6521.A states: "...The costs of publication shall be borne by the applicant."

Pursuant to LAC 33:IX.1309.I, LAC 33:IX.6509.A.1 and LAC 33:I.1701, you must pay any outstanding fees to the Department. Therefore, you are encouraged to verify your facility's fee status by contacting LDEQ's Office of Management and Finance, Financial Services Division at (225) 219-3863. Failure to pay in the manner and time prescribed could result in applicable enforcement actions as prescribed in the Environmental Quality Act, including, but not limited to revocation or suspension of the applicable permit, and/or assessment of a civil penalty against you.

Should you have any questions concerning any part of the draft modification(s), please feel free to contact Melanie Connor, Office of Environmental Services, at the address on the preceding page or telephone (225) 219-3088. All future correspondence regarding this permit shall use the Agency Interest (AI) number 687 and LPDES permit number LA0003191.

Sincerely,



Jesse Chang
Environmental Scientist Manager
Industrial Water Permits

MBC

Attachment(s) including, public notice, and factsheet:

cc: Scott Guilliams
Cheryl LeJuene
Water Permits Division

c: Melanie Connor
Water Permits Division

IO-W File

Sondra McDonald (6WQ-AT)
U.S. Environmental Protection
Agency, Region VI

Permit Compliance Unit
Office of Environmental Compliance

Public Notice Scheduled for Publication

The notice associated with the following:

**PUBLIC NOTICE FOR EXTENSION OF PUBLIC COMMENT
ON A DRAFT WATER DISCHARGE PERMIT
ENTERGY LOUISIANA, LLC
LITTLE GYPSY GENERATING PLANT
JEFFERSON PARISH, LOUISIANA
AI 687 / LA 0003191 / PER20060002**

is scheduled to publish in the following paper (s)

Newspaper(s)	Scheduled Publication Date*
St. Charles Herald-Guide	Thursday, March 15, 2007

In accordance with **LAC 33:IX.6521.A**, the applicant is responsible for payment of all costs of publication. Newspaper will bill applicant directly. Questions regarding publication or payment may be directed to:

DEQ Office of Environmental Services, Public Participation Group Staff:

Name: Barbara Mason

Phone: (225) 219-3280

Email: barbara.mason@la.gov

Comments:

***Actual date of publication is pending confirmation of publication by newspaper(s)**

PUBLIC NOTICE
LOUISIANA DEPARTMENT OF ENVIRONMENTAL QUALITY (LDEQ)
ENTERGY LOUISIANA, L.L.C. / LITTLE GYPSY GENERATING PLANT
DRAFT WATER DISCHARGE PERMIT MODIFICATION

The LDEQ, Office of Environmental Services, is accepting written comments on a draft permit modification of a Louisiana Pollutant Discharge Elimination System (LPDES) permit prepared for Entergy Louisiana, L.L.C., Little Gypsy Generating Plant, Post Office Box 61000, Mail Unit L-ENT-5E, New Orleans, Louisiana 70161. The facility is located at **17440 River Road in Montz, St. Charles Parish.**

The principal discharge from this existing source is made into the Mississippi River (Outfalls 001 and 006), waters of the state classified for primary contact recreation, secondary contact recreation, fish and wildlife propagation, and drinking water supply; and to Lake Pontchartrain via local drainage (Outfalls 002 - 005), waters of the state classified for primary contact recreation, secondary contact recreation and fish and wildlife propagation. Under the SIC Code 4911, the applicant proposes to modify its LPDES permit by revising the stormwater requirements for Outfalls 004, 005 and 006, and the stormwater pollution prevention plan language found in Part II, Paragraph O. Further, the modification changes the company name to Entergy Louisiana, L.L.C.

During the preparation of this permit, it has been determined that the discharge will have no adverse impact on the existing uses of the receiving waterbody. As with any discharge, however, some change in existing water quality may occur.

This permit is being modified to **REVISE THE STORMWATER REQUIREMENTS FOR OUTFALLS 004, 005 AND 006, AND THE STORMWATER POLLUTION PREVENTION PLAN LANGUAGE FOUND IN PART II, PARAGRAPH O. FURTHER, THE MODIFICATION CHANGES THE COMPANY NAME TO ENTERGY LOUISIANA, L.L.C.** In accordance with LAC 33:IX.3105.B.2, only those permit limitation and conditions pertaining to the draft modifications are open to public comment.

Written comments, written requests for a public hearing or written requests for notification of the final decision regarding this permit action may be submitted to Ms. Soumaya Ghosn at LDEQ, Public Participation Group, P.O. Box 4313, Baton Rouge, LA 70821-4313. **Written comments and/or written requests must be received by 12:30 p.m., Tuesday, April 17, 2007.** Written comments will be considered prior to a final permit decision.

If LDEQ finds a significant degree of public interest, a public hearing will be held. LDEQ will send notification of the final permit decision to the applicant and to each person who has submitted written comments or a written request for notification of the final decision.

The draft permit modification, application and fact sheet are available for review at the LDEQ, Public Records Center, Room 127, 602 North 5th Street, Baton Rouge, LA. Viewing hours are from 8:00 a.m. to 4:30 p.m., Monday through Friday (except holidays). **The available information can also be accessed electronically on the Electronic Document Management System (EDMS) on the DEQ public website at www.deq.louisiana.gov.**

Inquiries or requests for additional information regarding this permit action should be directed to Melanie Connor, LDEQ, Water Permits Division, P.O. Box 4313, Baton Rouge, LA 70821-4313, phone (225) 219-3088.

Persons wishing to be included on the LDEQ permit public notice mailing list or for other public participation related questions should contact the Public Participation Group in writing at LDEQ, P.O. Box 4313, Baton Rouge, LA 70821-4313, by email at maillistrequest@ldeq.org or contact the LDEQ Customer Service Center at (225) 219-LDEQ (219-5337).

Permit public notices including electronic access to the draft permit and fact sheet can be viewed at the LDEQ permits public notice webpage at www.deq.state.la.us/news/PubNotice/ and general information related to the public participation in permitting activities can be viewed at www.deq.louisiana.gov/portal/tabid/2198/Default.aspx.

Alternatively, individuals may elect to receive the permit public notices via email by subscribing to the LDEQ permits public notice List Server at http://www.state.la.us/ldbc/listservpage/ldeq_pn_listserv.htm.

All correspondence should specify AI Number 687, Permit Number LA0003191, and Activity Number PER20060002.

Schedule Publication date: March 15, 2007



PERMIT NUMBER:

LA0003191

AI 687

OFFICE OF ENVIRONMENTAL SERVICES

Water Discharge Permit

Pursuant to the Clean Water Act, as amended (33 U.S.C. 1251 et seq.), and the Louisiana Environmental Quality Act, as amended (La. R. S. 30:2001 et seq.), rules and regulations effective or promulgated under the authority of said Acts, and in reliance on statements and representations heretofore made in the application, a Louisiana Pollutant Discharge Elimination System permit modification is issued authorizing

Entergy Louisiana, L.L.C.
Little Gypsy Generating Plant
Post Office Box 61000, Mail Unit L-ENT-5E
New Orleans, Louisiana 70161

Type Facility: Steam Electric Generating Station

Location: 17440 River Road in Montz
St. Charles Parish

Receiving Waters: Mississippi River (Outfall 001 and Outfall 006)
Lake Pontchartrain via local drainage (Outfalls 002 – 005)

to discharge in accordance with effluent limitations, monitoring requirements, and other conditions set forth in Parts I and II (as applicable) attached hereto.

This permit and the authorization to discharge were effective on October 1, 2002 and shall expire five (5) years from the original effective date of the permit.

This permit has not been previously modified.

This modification shall become effective on _____

Issued on _____

DRAFT

Chuck Carr Brown, Ph.D.
Assistant Secretary

GALVEZ BUILDING · 602 NORTH 5th STREET · P.O. BOX 4313 · BATON ROUGE, LA 70821-4313 · PHONE (225) 219-3181

PART I

Draft Modified Page 7 of 9

Permit No. LA0003191

AI No. 687

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

During the period beginning upon exceedance of benchmark concentrations in accordance with the requirements specified by Part II, Paragraph O.6 and lasting through the expiration date, the permittee is authorized to discharge from:

Outfall 004, the intermittent discharge of low contamination potential stormwater runoff from industrial and non-industrial portions of the Little Gypsy switchyard.

Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	STORET Code	Discharge Limitations				Monitoring Requirements	
		(lbs/day, UNLESS STATED)		(mg/L, UNLESS STATED)		Measurement Frequency(*1)	Sample Type
		Monthly Average	Daily Maximum	Monthly Average	Daily Maximum		
Flow-MGD	50050	Report	Report	---	---	1/quarter	Estimate
TOC	00680	---	---	---	50	1/quarter	Grab
Oil and Grease	03582	---	---	---	15	1/quarter	Grab
pH Minimum/Maximum Values (Standard Units)	00400	---	---	6.0(*2) (Min)	9.0(*2) (Max)	1/quarter	Grab

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

Outfall 004, at the point of discharge from the east ditch prior to entering the parish drainage system.

FOOTNOTE(S):

(*1) When discharging.

(*2) The permittee shall report on the Discharge Monitoring Report both the minimum and maximum instantaneous pH values measured.

PART I

Draft Modified Page 8 of 9

Permit No. LA0003191

AI No. 687

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

During the period beginning upon exceedance of benchmark concentrations in accordance with the requirements specified by Part II, Paragraph O.6 and lasting through the expiration date the permittee is authorized to discharge from:

Outfall 005, the intermittent discharge of low contamination potential stormwater runoff from industrial and non-industrial portions of the facility's west ditch including non-contaminated stormwater runoff from the fuel oil storage dike.

Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirements	
	STORET Code	(lbs/day, UNLESS STATED)		Other Units (mg/L, UNLESS STATED)		Measurement Frequency(*1)	Sample Type
		Monthly Average	Daily Maximum	Monthly Average	Daily Maximum		
Flow-MGD	50050	Report	Report	---	---	1/quarter	Estimate
TOC	00680	---	---	---	50	1/quarter	Grab
Oil and Grease	03582	---	---	---	15	1/quarter	Grab
pH Minimum/Maximum Values (Standard Units)	00400	---	---	6.0(*2) (Min)	9.0(*2) (Max)	1/quarter	Grab

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

Outfall 005, at the point of discharge from the west ditch prior to entering the parish drainage system.

FOOTNOTE(S):

(*1) When discharging.

(*2) The permittee shall report on the Discharge Monitoring Report both the minimum and maximum instantaneous pH values measured.

PART I

Draft Modified Page 9 of 9
Permit No. LA0003191
AI No. 687

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

During the period beginning upon exceedance of benchmark concentrations in accordance with the requirements specified by Part II, Paragraph O.6 and lasting through the expiration date the permittee is authorized to discharge from:

Outfall 006, the intermittent discharge of low contamination potential stormwater runoff from portions of the infrequently used fuel oil unloading facility.

Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirements	
	STORET Code	Other Units				Measurement Frequency(*1)	Sample Type
		(lbs/day, UNLESS STATED) (mg/L, UNLESS STATED)					
		Monthly Average	Daily Maximum	Monthly Average	Daily Maximum		
Flow-MGD	50050	Report	Report	---	---	1/quarter	Estimate
TOC	00680	---	---	---	50	1/quarter	Grab
Oil and Grease	03582	---	---	---	15	1/quarter	Grab
pH Minimum/Maximum Values (Standard Units)	00400	---	---	6.0(*2) (Min)	9.0(*2) (Max)	1/quarter	Grab

There shall be no discharge of floating solids or visible foam in other than trace amounts.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

Outfall 006, at the point of discharge from the drainage valve of the fuel unloading facility prior to entering the Mississippi River.

FOOTNOTE(S):

(*1) When discharging.

(*2) The permittee shall report on the Discharge Monitoring Report both the minimum and maximum instantaneous pH values measured.

Part II

Draft Modified Page 9 of 20
Permit No. LA0003191 / AI 687

OTHER REQUIREMENTS (continued)

- e. All storage tank installations (with a capacity greater than 660 gallons for an individual container, or 1,320 gallons for two or more containers in aggregate within a common storage area) shall be constructed so that a secondary means of containment is provided for the entire contents of the largest tank plus sufficient freeboard to allow for precipitation. Diked areas should be sufficiently impervious to contain spills.
 - f. All diked areas surrounding storage tanks or stormwater collection basins shall be free of residual oil or other contaminants so as to prevent the accidental discharge of these materials in the event of flooding, dike failure, or improper draining of the diked area. All drains from diked areas shall be equipped with valves which shall be kept in the closed condition except during periods of supervised discharge.
 - g. All check valves, tanks, drains, or other potential sources of pollutant releases shall be inspected and maintained on a regular basis to assure their proper operation and to prevent the discharge of pollutants.
 - h. The permittee shall assure compliance with all applicable regulations promulgated under the Louisiana Solid Waste and Resource Recovery Law and the Hazardous Waste Management Law (L.R.S. 30:2151, etc.). Management practices required under above regulations shall be referenced in the SWP3.
 - i. The permittee shall amend the SWP3 whenever there is a change in the facility or change in the operation of the facility which materially increases the potential for the ancillary activities to result in a discharge of significant amounts of pollutants.
 - j. If the SWP3 proves to be ineffective in achieving the general objectives of preventing the release of significant amounts of pollutants to water of the state, then the specific objectives and requirements of the SWP3 shall be subject to modification to incorporate revised SWP3 requirements.
6. Facility Specific SWP3 Conditions:

The permittee must conduct benchmark monitoring for all stormwater outfalls that are covered exclusively under the SWP3 (i.e. stormwater outfalls not effective in Part I of this LPDES permit), in accordance with the following requirements:

Parameter	Benchmark Monitoring Cutoff Concentration	Frequency
Total Recoverable Iron	1.0 mg/l	1/year
TOC	50.0 mg/l	1/year
Oil & Grease	15.0 mg/l	1/year
pH	6.0 (min) - 9.0 (max) s.u.	1/year